SIEMENS Energy

TVM **6005c**

Test Documents for Vacuum Circuit-Breaker 3AE1002-2Z M50 (7.2 kV, 16 kA, 1250 A)

The vacuum circuit-breakers of type 3AE were type tested in accordance with

IEC Publication 62271-1, Edition 1.0, 2007-10,
IEC Publication 62271-100, Edition 2.0, 2008-04 and the relevant harmonisation documents.

For vacuum circuit-breaker 3AE1002-2Z M50 the following test documents are valid:

Type Tests	Rated Values	Test Documents
Dielectric tests	U_P = 60 kV U_d = 20 kV	09-001-MH/E
Temperature-rise tests	I_r = 1250 A	1135.2081027.576
Mechanical operation test at ambient temperature, Low and high temperature tests	10.000 op. Cycles -5 / +55 °C	05-042-MM/E
Short-time withstand current and peak withstand current tests	I_{sc} = 16 kA/3s I_{ma} = 40 kA	05-041-MS/E
Short-circuit making and breaking tests	I_{sc} = 16 kA I_{ma} = 40 kA	05-035-MS/E

Anger
E D MV C I PM B

Berlin, December 09, 2009

Siemens AG
Energy Sector; Leitung: Wolfgang Dehen
Power Distribution Division; Leitung: Ralf Christian
Medium Voltage; Leitung: Wolfgang Heuring

Nonnendammallee 104
13629 Berlin
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Peter Löscher, Vorsitzender;
Wolfgang Dehen, Heinrich Hiesinger, Joe Kaeser, Barbara Kux, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmssen
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684
WEEE-Reg.-Nr. DE 23691322

Test Documents for Vacuum Circuit-Breaker 3AE1002-2Z M50 (7.2 kV, 16 kA, 1250 A)

If a test is carried out with a vacuum circuit-breaker with different order number, the validity of the test document is given by the following statements:

The listed test documents for the mentioned vacuum circuit-breaker are valid in respect to familiar design of the vacuum circuit-breakers, as the construction of the main current path and mechanical driving mechanism is nearly identical.

Anger
E D MV C I PM B

Berlin, December 09, 2009

Siemens AG
Energy Sector; Leitung: Wolfgang Dehen
Power Distribution Division; Leitung: Ralf Christian
Medium Voltage; Leitung: Wolfgang Heuring

Nonnendammallee 104
13629 Berlin
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Peter Löscher, Vorsitzender;
Wolfgang Dehen, Heinrich Hiesinger, Joe Kaeser, Barbara Kux, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmssen
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684
WEEE-Reg.-Nr. DE 23691322

Test Documents for Vacuum Circuit-Breaker 3AE1002-2Z M50 (7.2 kV, 16 kA, 1250 A)

In addition to the type tests in accordance with IEC 62271-1 and IEC 62271-100 the following tests were carried out:

Type Tests	Test Documents
Single-phase and double earth fault tests	05-035-MS/E
Capacitive current switching tests: -cable-charging current breaking tests -single capacitor bank switching tests	06-055-MS/E
Out-of-phase making and breaking tests	06-024-MS/E

Anger
E D MV C I PM B

Berlin, December 09, 2009

Siemens AG
Energy Sector; Leitung: Wolfgang Dehen
Power Distribution Division; Leitung: Ralf Christian
Medium Voltage; Leitung: Wolfgang Heuring

Nonnendammallee 104
13629 Berlin
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Peter Löscher, Vorsitzender; Wolfgang Dehen, Heinrich Hiesinger, Joe Kaeser, Barbara Kux, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmssen
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684
WEEE-Reg.-Nr. DE 23691322