中国国家强制性产品认证证书

证书编号：2004010307126316

委托人名称、地址

苏州西门子电器有限公司

江苏省苏州新区珠江路455号

生产者（制造商）名称、地址

苏州西门子电器有限公司

江苏省苏州新区珠江路455号

生产企业名称、地址

苏州西门子电器有限公司

江苏省苏州新区珠江路455号

产品名称和系列、规格、型号

空气断路器

3WT8;详见参数附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则CNCA-C03-02:2014的要求，特发此证。

发证日期：2017年06月29日　　有效期至：2020年04月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2004年08月10日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询

主　任：

中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心

http://www.cqc.com.cn　　中国·北京·南四环西路188号9区 100070　　电话：+86 10 83886666

Q 1735259

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2004010307126316

NAME AND ADDRESS OF THE APPLICANT

Siemens Electrical Apparatus Ltd.Suzhou

No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Siemens Electrical Apparatus Ltd.Suzhou

No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Siemens Electrical Apparatus Ltd.Suzhou

No.455 Zhujiang Road, New District, Suzhou, Jiangsu Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Air Circuit-Breaker

3WT8;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jun.29,2017 **Valid until:** Apr.16,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.10,2004

The certificate information is available through CNCA's website: www.cnca.gov.cn

President: Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

http://www.cqc.com.cn Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666

Q 1735259

中国国家强制性产品认证证书

附　　录　　第 1 页 共 2 页

证书编号：2004010307126316　　纸　号：1735259

3WT8;
Ue：AC500V/AC690V；Ui：1000V；Uimp：12kV；
In：固定式：630A、800A、1000A、1250A、1600A、2000A、2500A、3200A、4000A，
抽屉式：630A、800A、1000A、1250A、1600A、2000A、2500A、3200A、3800A；
AC500V：Ics=Icu=66kA，Icw=66kA/1s(抽屉式/固定式)，Icw=66kA/0.5s(抽屉式)
AC690V：Ics=Icu=50kA，Icw=50kA/1s(抽屉式/固定式)（630A~4000A）
AC690V：Ics=Icu=66kA，Icw=66kA/1s(抽屉式/固定式)（630A~2500A）
过电流脱扣器类型：电子式；
使用类别：B 类；
极数：3P，4P；产品具有隔离功能
符合附录 N 的电子附件：
欠压脱扣器 UVR：Us：DC24V/110-125V/220-250V，AC110-127V/220-240V/380-415V；
配用的辅助触头（2NO+2NC、2NO+2NC+2CO、4NO+4NC、5NO+3NC、6NO+2NC）：
Ith=Ie；AC-12：Ue/Ie：AC24V/10A，AC48V/10A，AC110V/10A，AC230V/10A，AC400V/10A；
AC-15：Ue/Ie：AC24V/6A，AC48V/6A，AC110V/6A，AC230V/6A，AC400V/3A；
DC-12：Ue/Ie：DC24V/10A，DC48V/5A，DC110V/2.5A，DC230V/1A；
DC-13：Ue/Ie：DC24V/3A，DC48V/1.5A，DC110V/0.7A，DC230V/0.3A；

注：此附录与证书同时使用时有效。

主　任：

中国质量认证中心

http://www.cqc.com.cn　　中国・北京・南四环西路188号9区 100070　　电话：+86 10 83886666

中国国家强制性产品认证证书

附　　录　　第 2 页 共 2 页

证书编号：2004010307126316　　纸　号：1735259

型号的解释：

3WT8 40 6 - 5 U G 3 2 - 5AA1

第 1~4 位：型号名称

第 5、6 位：额定电流 06:630A；08:800A；10:1000A；12:1250A；16:1600A；20：2000A；25：2500A；32：3200A；40：3800A/4000A

第 7 位：分断能力及极数 S 型分断，　2—（框架 II,3 极）；6—（框架 II,4 极）

第 8 位：电子脱扣器

4- 无电子脱扣器，符合标准 GB14048.2（2008）中附录 L（无过电流保护要求的断路器），是从原体断路器省去过电流脱扣器（Y 级）而派生的，其额定限制短路电流（Icc）符合条件：Icc 等于原体断路器的 Icw。

5—ETU35WT；6—ETU37WT；7—ETU45WT；8—ETU47WT

第 9 位：　操作机构

A/B/E/F/G/K/U/L/Q/T 分别代表手动操作机构/电动操作机构/合闸线圈的不同组合

第 10 位：第一辅助脱扣器及欠压脱扣器

A/B/F/G/H/M/N/P/U/V/W 分别代表分励脱扣器/欠压脱扣器的不同类别

第 11 位：第二辅助脱扣器

0/1/2/3/4/5/6/7 分别代表第 2 分励脱扣器/辅助触头的不同组合

第 12 位：固定/抽屉式断路器：

0：固定式，母排水平后置；

2：固定式，母排垂直后置；

3：抽屉式，不带框架；

4：抽屉式，母排水平后置；

6：抽屉式，母排垂直后置；

8：抽屉式，母排后置，上部水平，下部垂直。

第 13~16 位：断路器附件

注：此附录与证书同时使用时有效。

主　任：

中国质量认证中心