

Test specification of the technical function „Temperature“

SIMATIC PCS 7

Test log • August 2012

Applikationen & Tools

Answers for industry.

SIEMENS

Siemens Industry Online Support

This article is taken from the Siemens Industry Online Support. The following link takes you directly to the download page of this document:

<http://support.automation.siemens.com/WW/view/en/33412955>

You can also actively use our Technical Forum from the Siemens Industry Online Support regarding this subject. Add your questions, suggestions and problems and discuss them together in our strong forum community:

<http://www.siemens.com/forum-applications>

Warranty and liability

Note

The Application Examples are not binding and do not claim to be complete regarding the circuits shown, equipping and any eventuality. The Application Examples do not represent customer-specific solutions. They are only intended to provide support for typical applications. You are responsible for ensuring that the described products are used correctly. These application examples do not relieve you of the responsibility to use safe practices in application, installation, operation and maintenance. When using these Application Examples, you recognize that we cannot be made liable for any damage/claims beyond the liability clause described. We reserve the right to make changes to these Application Examples at any time without prior notice.

If there are any deviations between the recommendations provided in these application examples and other Siemens publications – e.g. Catalogs – the contents of the other documents have priority.

We do not accept any liability for the information contained in this document.

Any claims against us – based on whatever legal reason – resulting from the use of the examples, information, programs, engineering and performance data etc., described in this Application Example shall be excluded. Such an exclusion shall not apply in the case of mandatory liability, e.g. under the German Product Liability Act (“Produkthaftungsgesetz”), in case of intent, gross negligence, or injury of life, body or health, guarantee for the quality of a product, fraudulent concealment of a deficiency or breach of a condition which goes to the root of the contract (“wesentliche Vertragspflichten”). The damages for a breach of a substantial contractual obligation are, however, limited to the foreseeable damage, typical for the type of contract, except in the event of intent or gross negligence or injury to life, body or health. The above provisions do not imply a change of the burden of proof to your detriment.

Any form of duplication or distribution of these Application Examples or excerpts hereof is prohibited without the expressed consent of Siemens Industry Sector.

Table of contents

	Warranty and liability	4
1	Introduction	6
2	Test Specification	7
	2.1 Preparations	7
	2.2 Test Specification of Control Strategies	8
3	Activities	10
4	History	11

1 Introduction

- This test specification does not include equipment module (EM)-specific test points, but it provides generally valid instructions for how the realized software (in CFC/SFC/WinCC) is to be tested against the EM type properties described in the specifications. This test specification can thus be used for all EM types.
- The test cases may have references to the dedicated chapter in the Functional Specification
- Each EM type has connections to the assigned CMs. These connections must exist before testing the EM.
- Before testing, it should be defined which signals are to be simulated in which way. To contain testing efforts and to focus the testing person's concentration on the actual test, it is advisable that at least all checkback messages from the CMs be generated automatically.
- It is required for testing to have the EM available in the CFC, the SFC and the OS
- When using the EM with SIMATIC BATCH, it is also required that the EM be available in SIMATIC BATCH for the test.

Onlinetest with following test environment

- SIMATIC S7-400 with CPU 417-4 (simulated)
- PCS 7 ES with the latest SIMATIC PCS 7 version

Execution

- Execution of test cases according to test specification (Input / output behaviour; operate and control functions).
- Deviations must be written into the action field.
- The SFCs test will be executed in the mode „T and B“ (step mode)

2 Test Specification

2.1 Preparations

Table 2-1

Test case	Description of test case	Test result			Comment
		Fulfilled	Not fulfilled	See chapter „Activities“	
1.0	Usage of the valid Functional Specification of the EM type. Please note the version of the SFC type.				Version: 1.0
1.1	Please note the FB number				FB No: 1026
1.2	Choose an instance of the EM and note the name and the path (CFC and function block).				Name of instance: R123_Temperature\EM
1.3	Please check if all assigned CMs are connected to the EM instance. Reference: CM configuration				
1.4	Please check if all parameter and timers are configured according to the Functional Specification. Please note all values of the parameters and timers. Reference: Parameter, Timer				Values of parameters see print-out Values of : timers see print-out
1.5	Please check, if all configured limits of the setpoints are reasonable (high, low) and note these test parameters.				Values of limits: See print-out
1.6	Please check, if all messages, message texts and message classes are according to the Functional Specification Reference: Standard SFC type messages, individual messages				

2.2 Test Specification of Control Strategies

Control Strategy 1 (control mode manual)

Table 2-2

Test case	Description of test case	Test result			Comment
		Fulfilled	Not fulfilled	See chapter „Activities“	
2.0	Please note the control strategy				Control Strategy: Temperature_Control
2.1	Please open the faceplate of the EM and check, if after choosing the control strategy for preparation the assigned setpoint parameters are available. Reference: Setpoints				
2.2	Please prepare the setpoint parameters of the control strategy and note the setpoint parameters (this test case may have different operating points) Please start the control strategy (via the faceplate) and check, if all steps and transitions are executing according to the Functional specification (steady-state operation). Please check in particular the status displays, the states, the steps and the position texts according to the Functional Specification. Reference: Control Strategy 1				
2.3	COMPLETE: In case of a not self-terminating EM, please execute the operation "COMPLETE" manually (via faceplate). The status „Completed“ will be established. Reference: Control Strategy 1				
2.4	HOLD: Please start the control strategy (via the faceplate). Execute the manual operation „HOLD“ while the EM is in the status „Run“. Please check, if the status „Held“ is established (check in sequence and faceplate) Reference: Control Strategy 1				
2.5	RESUME: Please execute the manual operation „RESUME“ while the EM is in the status „Held“. Reference: Control Strategy 1				

Test case	Description of test case	Test result			Comment
2.6	<p>ABORT:</p> <p>Please start the control strategy (via the faceplate). Execute the manual operation „ABORT “ while the EM is in the status „Run“.</p> <p>Please check, if the status „Aborted“ is established (check in sequence and faceplate)</p> <p>Reference: Control Strategy 1</p>				
2.7	<p>STOP:</p> <p>Please start the control strategy (via the faceplate). Execute the manual operation „STOP“ while the EM is in the status „Run“.</p> <p>Please check, if the status „Stopped“ is established (check in sequence and faceplate)</p> <p>Reference: Control Strategy 1</p>				
2.8	<p>ERROR:</p> <p>Please start the control strategy (via the faceplate).</p> <p>Simulate an error by setting the lock input of the interlock function block in the CFC to 1.</p> <p>Please check, if the status „Held (Error)“ is established (check in sequence and faceplate)</p> <p>Reference: Control Strategy 1</p>				
2.9	<p>RESET ERROR:</p> <p>Reset Error and resume the EM</p> <p>Please check, if the return to the run sequence is according the Functional specification.</p> <p>Reference: Control Strategy 1</p>				
Optional					
2.10	<p>If a active change of a control strategy is foreseen, please check all possibilities according the functional specification:</p> <p>Please start the control strategy (via the faceplate). Execute active change of control strategy according to the functional specification.</p> <p>In “Starting/Run” mode, perform a change of control strategy.</p> <p>Reference: Control Strategy 1</p>				

Control Strategy 1 (control mode Auto / Batch)

When using the EM in automatic mode and/or with SIMATIC BATCH, this should be included in the test specification and considered.

3 Activities

Table 3-1

Ref. No.	Activity	Comment
1.		
2.		
3.		
4.		

4 History

Table 4-1

Version	Date	Modifications
V1.0	04/2009	First version
V2.0	06/2012	Update Design& PCS 7 V7.1/ V8.0